BULLETIN NO
STOCKHOLM 1991
ISRN KTH-BYT/R--91/163-SE
TRITA-BYT 91/0163
ISSN 0346-5918

163

DEPARTMENT OF

BUILDING TECHNOLOGY

THE ROYAL INSTITUTE OF TECHNOLOGY

Housing — Components
Studies of
polyurethane-insulated
one-family houses using
new building components

Ingemar Höglund
Sten Ljunggren
Göran Ottoson
Robert Öman

ISRN KTH-BYT/R--91/163-SE
TRITA-BYT 91/0163
ISSN 0346-5918

Housing — Components

Studies of polyurethane-insulated one-family houses using new building components

This paper is based on a report presented at the
International CIB W67 Symposium on "Energy,
Moisture and Climate in Buildings", 3-6 September 1990,
Rotterdam, The Netherlands

by

Ingemar Höglund, DSc, Professor
Sten Ljunggren, DSc, Adj. Professor
Göran Ottoson, M.Sc.Eng.
Robert Öman, M.Sc.Eng.

Reprinted from Building Research and Information. The International Journal of
Research, Development and Demonstration. Vol. 19, No. 5 1991

Diagrams: Birgitta Andersson
Photographs: Robert Öman
Jupiter 262 91 023
AB PP-Print, Stockholm 1991

Housing Components Studies of polyurethane- insulated one-family houses using new building components

**FAVOURABLE RESULTS ACHIEVED OVER A THREE YEAR
PERIOD IN LOW-ENERGY HOUSES WHILST STILL
MAINTAINING HIGH STANDARDS**

I. Höglund   S. Ljunggren   G. Ottoson   R. Öman

Professor Höglund and his colleagues from the Department of Building Technology at The Royal Institute of Technology, Stockholm, describe their research and demonstration work concerning the construction and monitoring of 39 single family houses built at Sigtuna, 40km north of the city, where it was possible to build relatively simple, economical, well-insulated and airtight houses which have a low energy consumption.

Le Professeur Höglund et ses collègues du Département de la Technologie du Bâtiment à l'Institut Royal de Technologie, Stockholm, décrivent leurs recherches et leur travail de démonstration concernant la construction et la contrôle de 39 habitations individuelles construites à Sigtuna, à 40 km au nord de la ville, où il était possible de construire des maisons assez simples, économiques, bien isolées et étanches à l'air, ayant une consommation basse d'énergie.

Research project

Two almost identically constructed and situated houses were chosen for this project (Fig. 1). In one of them, the 'experimental house', some new construction methods were specially employed. The other house, the 'reference house', retained in all respects the construction methods originally planned for this residential estate. Evaluation of the project covers both the houses in their entirety and the above-mentioned new technical construction methods. During the three-year evaluation period all the houses have been occupied.

Among the interesting details and problems which have been studied more closely in the field were the use of energy (in detail for two of the houses and in general for all the 39 houses), exhaust air heat pumps using floor heating coils, floor surface temperatures, moisture content in wooden sills, wooden studs and the concrete slab, thermal resistance, airtightness and sound insulation in wall and roof elements insulated with polyurethane as well as ventilation in the whole building and in individual rooms. Complementary studies have also been carried out into thermal resistance and airtightness in two other similar (but older) houses, four-years and seven-years-old respectively. New construction methods which have been studied in the experimental house are: windows containing the new material, aerogel; windows with manoeuvrable and transparent

low-emission plastic foil; and a new joint using a steel sill (allowing ventilation) between the wooden sill of the outer wall and the concrete slab. This paper is based primarily on a selection of the results (refs 1 and 2).

Description of the construction of the houses

The houses are two-storeyed, with foundations consisting of a concrete slab placed directly on the ground (Fig. 2). A carport and a small, unheated shed join the houses together, which were therefore built as link houses (Fig. 3). The houses are almost square in shape with a total floor space of 116 m². They are designed for four alternative extensions of the ground floor, which can add another 11–16 m² of floor space. The ceiling height is 2.3 m on both floors, which is somewhat lower than the standard 2.4 m.

The walls and roof consist of prefabricated sandwich elements insulated with polyurethane on a wooden frame. The wall elements are the same length as the sides of the house, i.e. about 8 m. The thickness of insulation is 120 mm for the walls and 195 mm for the roof (Figs 4 and 5).

The joints between the wall and roof elements and around the windows are sealed with polyurethane foam. The windows are triple-glazed, which is the normal

Fig. 1. Single family houses at Sigtuna, Sweden

standard in Sweden. There is 70 mm of a polystyrene foam layer under the concrete slab, with 100 mm round the edges.

The houses are equipped with mechanical exhaust air ventilation, with supply air intakes in the outer walls. An exhaust air heat pump heats a 220 litre water-heater. When house heating is needed, a small pump will circulate water directly from the water-heater through the floor coils (copper tubes) placed in the concrete slab. The heat produced by the exhaust air heat pump is thus used both for hot water and for central heating. In addition the houses have thermostat-controlled electric radiators; in other words, the heating system consists of a combination of direct electric radiators and an exhaust air heat pump. Practically all electricity consumed by the heat pump (as well as the recovered heat) is utilized, which is also confirmed by our results.

Examples of results

Energy Balance

In order to determine in detail the energy consumption in the two houses, readings have been taken every month

Fig. 2. Casting the concrete slab (March 1985)

of a total of 13 different meters (for electricity etc.) in each house. These readings have been corrected with respect to deviations in the outdoor temperature from a normal year. The annual consumption of bought energy indoors is 12 300 kWh per year for the reference house and 13 200 kWh per year for the experimental house (the family in the experimental house kept a higher room temperature and used more hot water). Thus the amount of energy consumed in both houses is low. A complete calculation of the houses' energy balance corresponds closely with the consumption measured. Figure 6 shows the energy balance for the reference house. Of the total energy input for the house (family), 20 900 kWh per year bought energy accounts for 59%, while heat recovered from exhaust air, utilized solar heat gain and body heat supplies the remaining 41%.

The exhaust air heat pump contributes greatly to the low consumption of energy. The amount of energy retrieved from the exhaust air is about 5400 and 6800 kWh per year respectively. The heat pump's coefficient of performance is 2.2 in the reference house and 2.4 in the experimental house. The families' hot water requirements are provided for in both houses entirely by the heat pump. However, the greater part of the energy produced by the heat pump is used for the floor heating coils: 7900 and 8800 kWh per year respectively. This means that the floor heating coils account for over 60% of the energy provided for heating, while the electric radiators use less than 40%.

Of the 39 houses, 14 have extensions of 11 to 16 m² which makes the average floor space for all 39 houses 120.5 m². During a normal year the place has the mean outdoor temperature 5.5 °C and 4110 degree-day (assuming that the indoor temperature is raised to 17 °C until the outdoor temperature exceeds 11 °C). The average (and the mean) of all energy bought and used indoors (heating, hot water and household electricity) in all the houses (values corrected for a normal year based on two years' readings) is 14 500 kWh per year or

Fig. 3. The picture above shows the house facades facing the street. The facades are of vertical wooden boarding. On the left, a cross-section of the house construction. The houses are prefabricated to a fairly high degree. The foundation elements, which are left in position, act as forms for the concrete slab which is cast on the spot. These foundation elements consist of a core of polystyrene foam surrounded by an outer layer of concrete reinforced with steel fibre and glassfibre

121 kWh m⁻² per year (52 300 MJ per year or 434 MJ m⁻² per year). However, the differences between the various households (houses) are considerable. If the lowest consumption (8800) is compared with the highest (19 200 kWh per year) the ratio is 1:2.2. The fact that energy consumption varies greatly between equivalent houses owing to the households' different living habits has been documented in previous investigations. Lundström (ref. 3) gives the ratio of 1:2 for households with the lowest and the highest consumption.

In short, the houses built at Sigtuna are energy-economical, in spite of the fact that these houses were not planned in the first place to give low energy consumption. The potential for further energy saving by technical improvements (thicker insulation etc.) is relatively limited. For many families, however, the potential for energy saving by means of altering living habits is considerable.

Thermal resistance and airtightness

With the use of polyurethane foam (polyurethane insulation) very low thermal conductivity values can be achieved, thanks to the use of another gas than air in the cells of the material. Usually (as in the Sigtuna house) CFC₁₁ (CFC-11) is used, which has a thermal conductivity of about 0.008 W/m·°C, i.e. about 1/3 of the value for still air. Using polyurethane foam makes it possible to have walls with the same thermal resistance much thinner than with mineral wool insulation. In the future, however, certain CFCs, including CFC₁₁, will probably be completely banned because of their environmental effects and replaced with other gases.

Thermal resistance and airtightness were determined for the two Sigtuna houses and two other similar houses which were four and seven years old when the measurements were made (1985–6). In every case the thermal

conductivity refers to 110–70 mm of polyurethane foam in prefabricated wall elements between 9 or 13 mm sheets of plasterboard. The wall element joints etc. are made almost airtight with urethane foam.

The thermal conductivity determined lies within the range 0.018–22 W/m·°C. This low value (after up to seven years) suggests that the thermal conductivity of polyurethane foam in practice deteriorates very slowly due to gas diffusion. Another study (ref. 4) draws similar conclusions.

The air leakage rate in the four houses was 0.3–1.4 air changes per h at 50 Pa pressure difference (Fig. 7). All the houses easily meet the requirements of the Swedish Code of Practice (≤ 3.0 air changes per h). The very good airtightness in the seven-year-old house (0.3 air changes per h) indicates that the building envelope, including insulated joints between the various building elements, can hardly have aged to a noticeable degree as far as airtightness is concerned after seven years.

Ventilation and the indoor climate

The Sigtuna houses have mechanical exhaust air ventilation with supply air intakes in the outer walls. The total projected exhaust air flow rate is 162 m³ h⁻¹, which corresponds to 0.64 air changes per hour. The total exhaust air flow rate was determined to be on average 12% lower in the reference house and 22% lower in the experimental house compared with the projected value. In practice there are often large deviations from the projected air flow, for which reason the Sigtuna house results are not surprising. However, a review and adjustment of the ventilation system seems to be warranted. Moreover, tracer gas measurements show that the air change for the whole house as well as the individual rooms is relatively constant regardless of wind and outdoor temperature, which is one favourable effect of

Figs 4 and 5. Both the wall and roof elements are prefabricated.

the exhaust air ventilation system in combination with the good airtightness of the houses.

Exhaust air ventilation leads on average to an underpressure of about 12 and 8 Pa in the reference and the experimental house respectively for the projected

exhaust air flow. The underpressure varies more or less with the total airtightness of the buildings (including the supply air intakes), the exhaust air flow, the thermals (chimney effect) and the wind. At an outdoor temperature of -20°C and 20°C indoors the thermals make a

Fig. 6. Energy input and energy losses in the reference house. The values are based on a combination of measured consumption and calculations. The energy input is shown in two different ways, where the column on the left shows the source of the energy, while the middle column shows how the energy is provided.

Energy for heating (19 300 kWh per year) covers the whole year (including the summer) with an average indoor temperature of 21 °C. The bought energy used for active space heating is only 8 000 kWh per year. The total consumption of bought energy is 12 300 kWh per year, which means that the family in this house uses 2 000 kWh per year less than the average for the 39 houses

pressure gradient of 1.9 Pa m⁻¹ or on average 4.8 Pa between the upper and lower storeys. Thus the thermals lead to the two storeys having differing degrees of ventila-

tion in the winter, with a smaller supply air flow rate to the upper storey. A calculation based on measurement data (related values for differences in pressure and air flow) has quantified this effect, which has proved to be significant. Both poorer airtightness and smaller exhaust air flow lead to lower air pressure indoors, which increases the relative effect of the thermals. In order to achieve a sufficiently constant supply air flow rate in a two-storeyed house with exhaust air ventilation, in spite of the effect of both thermals and wind, the underpressure indoors should not, at a rough estimate, be less than 10 Pa on average.

Both measured air and surface temperatures and practical experience prove that the thermal climate in the houses is good. The temperature of the air indoors has, in the winter, usually been between 19–20 °C in the reference house and 20 and 21 °C in the experimental house. These values hold good for all the rooms except the shower/laundry room on the ground floor, where heat from the water-heater etc. has resulted in a temperature a few degrees higher. Close to the supply air intakes (three on each storey) there is, however, a small zone of somewhat colder air in the winter, which to some extent restricts the way in which the houses can be furnished. Measurements and practical experience also

Fig. 7. Measurement of the air leakage rate.

Fig. 8. The floor temperatures were determined at one spot (a) on the ground floor of the experimental house on four different occasions. Alongside the date given is the outdoor temperature on that day. The indoor temperature was 19–20 °C (except for 1 April 1986, when it was 22 °C). The rise in temperature of the three floor heating coils is very evident. The occupants appreciated this higher temperature, which makes the floors more comfortable to walk on

show that the ventilation and the air quality are on the whole good. It is, however, important that the ventilation system is well maintained, since the air quality in the relatively airtight buildings is highly dependent on how well the mechanical ventilation system functions.

Figure 8 shows examples of the surface floor temperature in the experimental house on four different winter days when the floor heating coils were in use. Measurements were taken at every dm 0–2 m away from the outer wall. It is generally true to say that houses with a concrete slab directly on the ground and without floor heating often have a relatively low floor temperature just inside the outer walls on the ground floor because of thermal bridge effects, in spite of having a relatively well-insulated construction. Thanks to the floor heating coils there is in the Sigtuna houses, by contrast, a higher temperature which is very favourable

from the point of view of comfort and which makes it easier to make use of (furnish) the floor space right up to the outer walls. The rise in temperature inside the construction is also normally advantageous in order to avoid moisture problems.

Moisture in walls and the concrete slab

The risk of biological attacks on wood materials (rot, mould etc.) is to a large extent dependent on the moisture content. With a moisture content of less than 15% the risk is minimal. Just after the wall elements had been erected (March 1985) the moisture content was 20–29% in the pressure-impregnated wooden sills of the outer walls. The time it took for the wood to dry out to the average moisture content of 15% was 6 months for the reference house and 2.5 months for the experimental house. The rate of drying is shown in Fig. 9. The shorter

time it took for the experimental house to dry out is mainly explained by the placing of a steel sill (of corrugated stainless steel) (Fig. 10) between the wooden sill and the concrete slab, while the reference house had the conventional construction generally used in the estate of polyurethane foam between the wooden sill and the concrete. A short drying-out period reduces the risk of attacks from mould etc.

The inner wall sills dried very quickly from, in some cases, a very high level of moisture. Throughout the period the outer wall studs have had moisture content (at the measuring points) of between 8 and 12%. The

wall elements are, thanks to the polyurethane foam, airtight themselves, which means that no plastic film was used on the outer walls in this case. The dry outer wall studs and the relatively good airtightness of the houses indicate that the construction functions well without plastic film, which is also confirmed by laboratory experiments by (Larsson (ref. 6). As far as the concrete foundation slabs are concerned, both measurements and practical experience show that the concrete slab was sufficiently dry (with a moisture content corresponding to a relative humidity of <90%) to avoid damage to, for example, the plastic floor covering.

REF. HOUSE WITH PUR FOAM

Moisture content, % by weight, in outer wall sills

EXP. HOUSE WITH STEEL SILL

Moisture content, % by weight, in outer wall sills

Fig. 9. Moisture content measured in the outer wall sills of pressure-impregnated wood. The mean value (broad line) and the spread from the lowest to the highest value from six measuring points. The risk of biological attacks on the wooden sills (rot and mould) is marked with shading, where close shading represents a greater risk. As can be seen, the period of drying-out (of damp after the erection) is considerably shorter thanks to the steel sill-system, where the moisture content already after 2-3 months are below critical values. The steel sill is completely capillarity breaking between concrete and wood, and the wooden sills are ventilated (dried out) via air intakes in the corners of the house. After the short period of drying-out the air intakes are closed with special lids (ref. 7)

Fig. 10. A wall element is placed on the steel sill

Measurements of the air humidity show that the increase in moisture is relatively low, often about $2\text{--}3\text{ g m}^{-3}$ in the wet rooms and $1\text{--}2\text{ g m}^{-3}$ in the other rooms. This means that the relative humidity is fairly low indoors, and usually 20–40% in the winter.

Sound insulation

The outer walls of the Sigtuna houses consist, seen from inside, of 13 mm of plasterboard, 120 mm of polyurethane foam between $45\times 120\text{ mm}$ wooden studs, 9 mm of plasterboard, $22\times 70\text{ mm}$ wooden battens (i.e. 22 mm air space) and 22 mm wood panel on the outside. This construction is relatively light and at the same time fairly rigid, which implies that the sound insulation is poor. Conversations held inside the house can therefore be overheard outside the walls (Fig. 11).

After complaints had been made by the occupants, the wall towards the carport was insulated with an extra layer of mineral wool between 45×45 wooden studs, faced by $2\times 13\text{ mm}$ sheets of plasterboard. In addition, plasterboard was placed in the carport roof in order to reduce the flanking transmission. These simple improvements raised the apparent sound reduction index from $R'_{w30}\text{--}35\text{ dB}$ to $R'_{w50}\text{--}50\text{ dB}$.

These values do not directly say whether or not the sound insulation is now sufficiently good. In order to study this problem, speech intelligibility in the form of an 'articulation index', AI, was calculated in accordance with an American standard (ANSI 53.5–1969). The appropriate values for sound insulation and background level show that the additional insulation reduced the AI from 0.39 to 0.0. According to ANSI these values correspond to a speech intelligibility for sentences of 92% and 0% respectively. It is therefore evident that the additional insulation greatly raised the level of personal integrity.

The sound insulation of the original outer walls must thus be considered inadequate. However, both calculations and measurements show that a relatively simple improvement gives the walls an acceptable level of sound insulation.

Experiences and conclusions

On average during a normal year the 39 houses (households) used 14 500 kWh per year or 121 kWh m^{-2} , which includes all bought energy indoors (heating, hot water and household electricity). The average annual temperature at this location is 5.5°C . Exhaust air heat pumps contribute greatly to the low level of energy consumption. When comparing the households with the lowest

Fig. 11. Plan of the link houses in the project. This type of house plan obviously leads to the risk that conversations held in the bedroom or livingroom will be overheard in the neighbour's carport, particularly as there is no window in the wall concerned

and highest energy consumptions, however, the ratio is 1:2.2, although the differences between the technical quality of the house are relatively small. The fact that the consumption of energy varies greatly between equivalent houses as a result of the occupants' different living habits is thus confirmed (and quantified) in this study. The houses themselves are so energy-economical that the potential in economic terms for further energy saving by means of technical improvements (thicker insulation etc.) is relatively limited, but at the same time relatively high by means of altering the living habits of many families.

The determined coefficient of thermal conductivity of the polyurethane foam insulation in walls and roofs lies within the range of 0.018–22 W/m²·C. These low values (after up to seven years) indicate that the deterioration in the thermal conductivity of polyurethane foam in practice takes place very slowly.

The air leakage rate in four different polyurethane insulated houses was found to be 0.1–1.4 air changes per h at 50 Pa. The extremely good airtightness for a seven-year-old house (0.3 air changes per h) indicates that the building envelope including the joints between the various house elements, can hardly have aged noticeably as far as airtightness is concerned over a period of seven years.

One problem connected with PUR-insulated constructions is, however, that they are light and at the same time relatively rigid. This implies that the sound insulation will be poor if improvements are not made.

Houses with a concrete slab directly on the ground and without floor heating often have a low floor temperature close to the outer walls of the ground floor because of thermal bridge effects, in spite of a well-insulated construction. Thanks to the underfloor heating coils there is, in contrast, a raised temperature in these houses, which is very advantageous from the point of view of comfort. The fact that the thermal climate in other respects is also good is shown by the measured air and surface temperatures and by practical experience. No damage or problems caused by moisture have been noted in these two houses. Measurements also show that critical constructions are sufficiently dry and that the air humidity indoors is relatively low.

The mechanical system or exhaust air ventilation gives a relatively constant air change rate, but the exhaust air flow rate in these two houses was on average somewhat lower than the projected values. The exhaust air ventilation system gives for the projected exhaust air flow about 12 and 8 Pa underpressure respectively on aver-

age in the two houses. A combination of measurements and calculations, however, shows that the effect of the thermals (chimney effect) is considerable, so that the two storeys in the winter have different levels of ventilation, with a smaller supply air flow rate to the upper storey. In order to achieve a sufficiently constant flow of air in a two-storied house ventilated by an exhaust air system, in spite of the effect of the thermals and of the wind, the underpressure indoors should not at a rough estimate, be less than 10 Pa on average.

To sum up, the results are favourable. It has been proved possible to build relatively simple, economical, well-insulated and airtight houses which have a low energy consumption. At the same time problems connected with moisture, mould and poor air quality for example—in other words problems associated with so-called sick buildings—have been avoided.

References

1. Höglund, I., Ottoson, G. and Öman, R., Sigtunaprojektet—byggfysikaliska, energitekniska och produktionstekniska studier av PUR-isolerade småhus med nya byggnadskomponenter. Department of Building Technology, The Royal Institute of Technology. Working Report. Stockholm 1990.
2. Höglund, I., Ottoson, G. and Öman, R., The energy balance in houses insulated with polyurethane presented at CIB W67 Workshop on Second Generation of Low-Energy Buildings in Different Climates, Stuttgart, June 1990.
3. Lundström, E., Occupant influence on energy consumption in single-family dwellings. Swedish Council for Building Research. Document D5:1986. Stockholm 1986.
4. Isberg, J., Sandwichelement av uretancellplast. Ytskiktets inverkan på förändringen av värmemotstånd med tiden. Swedish Council for Building Research. Report R69:1989. Stockholm 1989.
5. Larsson, L.-E., Sandwich panels with foamed polyurethane insulation, presented at CIB W67 Workshop "New Opportunities for Energy Conservation in Buildings", September 1987. Department of Building Technology, The Royal Institute of Technology. Bulletin No. 153. Stockholm 1988.
6. Larsson, L.-E., Sandwichelement av uretancellplast. Fuktvandningsförsök på laboratoriet vid varierande klimatförhållanden. Division of Building Construction, Chalmers Institute of Technology. Publication 81:4. Göteborg 1981.
7. Höglund, I. and Hyppel, A., New effective methods for clearing mould from sills presented at CIB W67 Symposium on Energy, moisture, climate in buildings, Rotterdam, September 1990.

- 1 *Kreuger H och Eriksson A*: Utredning rörande sambandet mellan cements tryckhållfasthet vid normenliga prov och tryckhållfastheten hos betong. 1923 (Särtryck ur Byggmästaren 1923)
- 2 *Kreuger H och Eriksson A*: Undersökningar å aluminatcement samt å bruk och betong, som därav framställts. 1924 (Särtryck ur Byggmästaren 1924)
- 3 *Kreuger H och Eriksson A*: Utredning rörande materialåtgången vid blandning av betong. 1924 (Särtryck ur Byggmästaren 1924)
- 4 *Kreuger H och Eriksson A*: Vattenuppsugnings- och uttorkningshastighet vid olika ytbehandling av tegelfasader. 1925 (Särtryck ur Byggmästaren 1925)
- 5 *Kreuger H*: Det frostfria djupets läge på olika orter i Sverige. 1925 (Särtryck ur Byggmästaren 1925)
- 6 *Kreuger H*: Ljudisoleringsundersökningar i Nordamerikas Förenta Stater. 1926 (Särtryck ur Byggmästaren 1926)
- 7 *Eriksson A*: Bostadsförhållandena i Stockholm 1927 (Särtryck ur Byggmästaren 1927)
- 8 *Kreuger H och Eriksson A*: Grafiska framställningar av undersökningsresultat. 1928 (Särtryck ur Nordisk Byggnadsdag 1927)
- 9 *Kreuger H*: Rumsakustik. 1929 (Sammandrag av föredrag)
- 10 *Kreuger H*: Hastig provning av cement och betong. 1929
- 11 *Kreuger H*: Akustiska spörsmål inom byggnadstekniken. 1929 (Sammandrag av föredrag)
- 12 *Kreuger H och Sager J H*: Undersökning av byggnadskonstruktioners isolerande förmåga mot stötljud. 1931 (Särtryck ur Byggmästaren 1931)
- 13 *Kreuger H och Sager J H*: Ventilationskanaler ur ljudisoleringssynpunkt. 1932 (Särtryck ur Byggmästaren nr 18, 1932)
- 14 *Kreuger H och Sager J H*: Ljud från rörledningar och metoder för deras dämpande. 1933 (Särtryck ur Byggmästaren nr 13, 1933)
- 15 *Kreuger H och Sager J H*: Metoder för mätning av vibrationer samt indelningsgrunder för deras styrka 1936 (Särtryck ur Byggmästaren nr 12, 1936)
- 16 *Kreuger H och Sager J H*: Om svängningar hos byggnader. 1938 (Särtryck ur Byggmästaren nr 1, 1938)
- 17 *Brandt O*: Mätmetoder för luft- och stötljuds-isolation. Ljudisolering i bostadshus av betong. 1949 (Särtryck ur Byggmästaren nr 2, 1948 och nr 3, 1949)
- 18 *Nevander L E*: Hållkraft hos träskruv. 1949 (Särtryck ur Byggmästaren nr 19, 1949)
- 19 *Brandt O*: Ljudisolering hos dörrar.
- 20 *Hast N*: Betydelsen för rumsventilation av fuktabsorberande material i rummet och dess begränsningsstor. 1954
- 21 *Nevander L E*: Tegelmurverk armerat med nat i liggfogarna. 1957
- 22 *Brosenius H*: Byggnadstekniska möjligheter att minska bostadskostnaderna. 1959 (Särtryck ur Väg- och Vattenbyggaren nr 1, 1959)
- 23 *Nevander L E*: Tekniska egenskaper hos isolerade hålmurar av tegel. 1961
- 24 *Höglund I och Lyng O*: Värmefflödesmätningar på högisolerade ytterväggar. 1961 (Särtryck ur Byggmästaren nr 8, 1960 och nr 2 och 8, 1961)
- 25 *Brandt O och Bring Ch*: Stegljudsisolering och beständighet mot intryck hos golvbeläggningar på massivbjälklag av betong. 1961 (Särtryck ur Byggmästaren nr 10, 1961)
- 26 *Nevander L E, Palm Y, Öberg S, Adamson B och Höglund I*: Köldbryggor i ytterväggar. 1961 (Särtryck ur Byggmästaren nr 2, 1961)
- 27 *Höglund I och Ottoson G*: Tre typer av kryputrymmen. 1961 (Särtryck ur Byggmästaren 1961)
- 28 *Höglund I och Elmroth A*: Bestämning av värmeförluster i småhus. 1961 (Särtryck ur Byggmästaren nr 11, 1961)
- 29 *Höglund I och Lyng O*: Nya fasader på gamla hus — tilläggsisolerade ytterväggar. 1963 (Särtryck ur Byggmästaren nr 3, 1963)
- 30 *Höglund I*: Högisolerande ytterväggars värmemotstånd. 1963
- 31 *Höglund I*: Värmeförluster i småhus — resultat från två försökshus. 1963
- 32 *Brosenius H och Nuder A*: Vertikalkommunikationer i höga bostadshus. En kostnadsundersökning. 1963 (Särtryck ur Byggmästaren nr 7, 1963)
- 33 *Bring Ch*: Data om golv. Material. Egenskaper. Krav. Läggnings. Ekonomi. 1963
- 34 *Nylund P O*: Fogmassor i betongfasader. Resultat av jämförande undersökningar. 1964 (Särtryck ur Byggmästaren nr 11, 1963)
- 35 *Höglund I och Hansson T*: Ny metod för differentiering av det praktiska värmeledningstalet för mineralull. 1964 (Särtryck ur Byggmästaren nr 2, 1964)
- 36 *Nuder A*: Kostnader för vertikalkommunikationer i bostadshus med 3—16 våningar — några tillämpningsexempel. 1964 (Särtryck ur Byggmästaren nr 2, 1964 och Byggnadsindustrin nr 6, 1964)
- 37 *Höglund I och Hansson T*: Inre konvektion i byggnadskonstruktioner — några studier speciellt av isolering med mineralull. 1964

- 38 *Nuder A*: Kostnad och utvärdering vid byggnadsekonomiska jämförelser. 1964 (Särtryck ur Byggmästaren nr 10, 1964)
- 39 *Höglund I*: On Thermal Insulation Properties of External Multilayer Walls. 1965
- 40 *Carlsson K*: Stomkonstruktioner i moderna kontorshus. 1965 (Särtryck ur Byggmästaren nr 5, 1965)
- 41 *Nuder A*: Hiss- och trappkostnader i bostadshus. 1965
- 42 *Brosenius H*: Om fönstereareor vid kontorshus.
Nuder A: Kontorshus i Stockholm. 1966 (Särtryck ur Byggmästaren nr 11, 1965)
- 43 *Jansson I*: Testing the Rate of Water Absorption. 1966 (Särtryck ur rapporter till RILEM/CIB-Symposium. Helsingfors 1965)
Elmroth A och Höglund I: Influence of Moisture on the Thermal Resistance of External Walls of Cellular Concrete — relating to two newer types of construction. 1966 (Särtryck ur rapporter till RILEM/CIB-Symposium. Helsingfors 1965)
- 44 *Brosenius H*: Värme-, fukt- och brandskyddsfrågor vid husbyggnader. 1966
- 45 *Elmroth A*: Fukt- och temperaturförhållanden i kryprum. 1966 (Särtryck ur Lättbetong nr 1, 1966)
- 46 *Nuder A och Johnsson B*: Hissar och trappor i kontorshus. 1966 (Särtryck ur Byggmästaren nr 6, 1966)
- 47 *Elmroth A och Höglund I*: Analys av icke stationära värmeströmsförhållanden för ett plant tak med RC-nätverksmetod. 1966 (Särtryck ur Byggmästaren nr 11, 1966)
- 48 *Brosenius H*: Vägg och bjälklagskonstruktioner vid husbyggnader. 1966
- 49 *Nuder A och Strömberg A*: Kostnader och värden inom byggnadsbranschen. Prisbildning inom bostadsbyggandet. 1967 (Särtryck ur Byggmästaren nr 8, 1966 och Byggnadsindustrin nr 18, 1966)
- 50 *Brosenius H*: Om flexibel vattenburen värme. 1973
- 51 *Nylund P O*: Vindtäthet hos flerskiktsväggar. 1967 (Särtryck ur Byggmästaren nr 11, 1966)
- 52 *Brosenius H*: Betonghus och elementbyggeri. 1967
- 53 *Bring Ch*: Vidhäftning mellan hårdnat betongunderlag och pågjutet golvsikt. 1967 (s. 101-112 särtryck ur Byggmästaren nr 4, 1966)
- 54 *Buo F, Elmroth A, Friström G och Sällström S*: Some investigations concerning winter concreting: Required insulation and prehardening time for concrete with low-heat cement. 1967 (Rapport till Neuvème Congrès des Grands Barrages, Istanbul 1967)
- 55 *Nuder A och Strömberg A*: Bostadsbyggande med eller utan markspekulation — en teoretisk analys. 1967 (Särtryck ur Väg- och vattenbyggaren nr 8-9, 1967)
- 56 *Brosenius H*: Stomkomplettering vid husbyggnader. 1967
- 57 *Höglund I*: Småhus i väster. 1968 (Särtryck ur Byggnadsvärlden nr 11, 15, 17/18, 27 och 37/38, 1967)
- 58 *Nylund P O*: Rörelser hos fasadelement av betong. 1968 (Särtryck ur Byggmästaren nr 5, 1968)
- 59 *Bring Ch*: Provningsmetoder för golvmaterial och golvkonstruktioner. 1968
- 60 *Brosenius H*: Konvektionsproblem och andra värmebalansfrågor. 1968
- 61 *Nylund P O*: Movements in joints. 1968 (Särtryck ur rapporter till CIB-symposium Weathertight joints for walls. Oslo 1967)
- 62 *Nuder A och Strömberg A*: Privat kooperativt eller allmännyttigt bostadsbyggande? 1968 (Särtryck ur Byggnadsindustrin nr 13, 1968)
- 63 *Höglund I och Stephenson D G*: Tabeller för beräkning av solinstrålning mot byggnader. 1968 (Kompletterat särtryck ur Byggmästaren nr 9, 1968)
- 64 *Elmroth A och Holmström B*: Värmelednings-tal för träullsplattor utan tätande ytskikt på den inre, varma sidan. 1968 (Särtryck ur Byggmästaren nr 9, 1968)
- 65 *Buo F, Elmroth A, Friström G och Sällström S*: Vintergjutning och formisolering vid vattenkraftanläggningar. 1968 (Särtryck ur Byggnadsindustrin nr 14, 1968)
Elmroth A: Tilläggsisolering av träformar vid vintergjutning. 1968 (Särtryck ur Väg- och Vattenbyggaren nr 10, 1966)
- 66 *Marian J-E, Ivansson B-O, Ström H, Fickler H-H och Helgesson G*: Das Keilzinken von Holz. 1968 (Särtryck ur Holz als Roh- und Werkstoff, bd 26, 1968, häfte 2, 3 och 5)
- 67 *Nuder A och Ivansson B-O*: Kontrollagen är borta. 1969 (Särtryck ur Väg- och Vattenbyggaren nr 1-2, 1969)
- 68 *Bring Ch*: Planhet och lutningar hos golv. Industrigolv och rullande stålhljul. Träskivor i löst lagda undergolv. 1969 (Särtryck ur Byggnadsindustrin nr 11-12, 1969)
- 69 *Höglund I, Rönning M och Norell T*: Värme-strålning och k-värden. 1969 (Särtryck ur Lättbetong nr 2, 1969)
- 70 *Elmroth A och Höglund I*: Analys av ofrivillig ventilation i småhus. 1970 (Särtryck ur VVS nr 2, 1970)
- 71 *Elmroth A och Höglund I*: Fuktskydd av kryprum genom markisolering. 1970 (Särtryck ur Byggmästaren nr 3, 1970)
- 72 *Brosenius H*: Optimal-ekonomisk projektering av byggnader och byggnadsdelar. 1970
- 73 *Nuder A*: Bostadsbyggande — ett fördelningsproblem. 1970 (Särtryck ur Kommunal Tidsskrift nr 10, 1969 och nr 1, 1970 samt Plan 5-6, 1969)

- 74 *Ivanesson B-O och Ström H*: Limträ (3 uppsatser). 1970 (Särtryck ur Svensk Snickeritidskrift nr 12-13, 1968 och nr 6, 1969 samt nr 20, 1969)
- 75 *Ivanesson B-O och Ström H*: Nytt sätt att bygga med gammalt material. 1970 (Särtryck ur Byggnadsindustrin nr 5, 1970)
- 76 *Elmroth A*: Skador och brister i småhusens klimatskydd. 1970 (Särtryck ur Väg- och vattenbyggaren nr 4, 1970)
- 77 *Johnsson B och Hedberg N*: Småhusbygget i tre Storstockholmskommuner. 1970 (Särtryck ur Väg- och vattenbyggaren nr 4, 1970)
- 78 *Brosenius H*: Energival vid småhusuppvärmning. Byggeforskningen Rapport R 32: 1970
- 79 *Johnsson B och Hedberg N*: Småhusupphandling med konsumentinflytande. 1970 (Särtryck ur Väg- och vattenbyggaren nr 4, 1970)
- 80 *Nuder A*: Värdeändringar för bebyggda fastigheter. 1970 (Särtryck ur Byggmästaren nr 4, 1970)
- 81 *Brosenius H*: Om uppvärmningssystem vid småhus. 1970 (Särtryck ur Väg- och vattenbyggaren nr 4, 1970)
- 82 *Rönnmark C*: Modernisering och förnyelse — en studie av saneringsalternativ. Statens Råd för Byggnadsforskning. 1970
- 83 *Nuder A och Johnsson B*: Kontorshus i Stockholm. Byggeforskningen Rapport R 16: 1970
- 84 *Ivanesson B-O och Ström H*: Industrialiserat bostadsbyggande i USA — 1. 1970 (Särtryck ur Byggmästaren nr 1-2, 1970)
- 85 *Ivanesson B-O och Ström H*: Industrialiserat bostadsbyggande i USA — 2. 1970 (Särtryck ur Byggmästaren nr 6 och 8, 1970)
- 86 *Elmroth A och Höglund I*: Värmegenomgångstal för hela fasadelement — en modifierad "Guarded Hot Box"-metod. 1970 (Särtryck ur Byggnadsvärlden nr 6, 1970)
- 87 *Johnsson B*: Kostnadsutvecklingen inom gruppshusbygget i Stor-Stockholm. 1970 (Särtryck ur Väg- och Vattenbyggaren nr 8-9, 1970)
- 88 *Ivanesson B-O och Johnsson B*: Gruppshusinriktad typhusindustri. 1970 (Särtryck ur Svensk Snickeritidskrift/Träförädlingen nr 11, 1970)
- 89 *Höglund I*: Metod för beräkning av extrema ytemperaturer hos lätta isolerade ytterkonstruktioner — med tillämpningsexempel avseende isolerade metalldeck. Rapport till Stålbyggnad — Nordiska forskningsdagar 1970 — Session V, 1970
- 90 *Ivanesson B-O och Ström H*: Trähusssystem i USA. 1970 (Särtryck ur Svensk Snickeritidskrift/Träförädlingen nr 6 och 12, 1970)
- 91 *Brosenius H*: Direkt elvärme eller flexibel vattenburen värme? (Särtryck ur Byggmästaren nr 10 och 11, 1970)
- 92 *Bing Ch*: Kvalitetskrav på golv i byggnadsprogram och byggnadsbeskrivningar. Byggeforskningen Rapport R 43:1971
- 93 *Elmroth A och Höglund I*: Småhusgrundläggning med kryprum — fukt, ventilation, temperatur. Byggeforskningens informationsblad B 13:1972
- 94 *Höglund I*: Metod för beräkning av extrema ytemperaturer hos isolerade ytterkonstruktioner. Byggeforskningen Rapport R 6:1973
- 95 *Elmroth A och Höglund I*: Värmebalans i småhus. Teoretiska och experimentella undersökningar avseende ett mineralullsisolerat regelhus. Byggeforskningen Rapport R 7: 1973
- 96 *Johnsson B*: Småhusens teknik och ekonomi. Byggeforskningen Rapport R 47:1972
- 97 *Elmroth A och Höglund I*: Nya källarytterväggar ger bostadsklimat under mark. 1971 (Byggeförlaget)
- 98 *Höglund I*: Extreme Surface Temperatures. 1973. First Heat Transfer Conference. Polytechnic Institute of Jassy, IASI
- 99 *Elmroth A och Höglund I*: Energy Conservation in Buildings. 1973. First Heat Transfer Conference. Polytechnic Institute of Jassy, IASI
- 100 *Höglund I et al*: Från grund till tak. 1973. Några forskningsarbeten vid institutionen för byggnadsteknik, KTH.
- 101 *Höglund I och Åhlgren B*: Fönsterteknik. 1973 (Byggeförlaget)
- 102 *Elmroth A och Höglund I*: Designing Houses for Energy Conservation (Reprinted from Building Research and Practice. March/April 1974)
- 103 *Höglund I*: Solenergi för byggnader. 1974 (Särtryck ur VVS nr 9, 1974)
- 104 *Höglund I*: Calculating extreme surface temperatures. 1975. (Reprinted from Building Research and Practice Nov/Dec, 1974)
- 105 *Elmroth A*: Kryprumsgrundläggning. Byggeforskningen Rapport R 12:1975
- 106 *Nylund P O*: Temperaturrelater hos fasadskivor. Byggeforskningen Rapport R 60:1975
- 107 *Höglund I och Isakson P*: Solvärme för hus — en utmaning. 1975 (Särtryck ur VVS nr 11, 1975)
- 108 *Höglund I och Johnsson B*: Byggnadstekniska och installationstekniska åtgärder för energibesparing i äldre byggnader. 1976
- 109 *Johnsson B*: Kommunupphandlade småhus i grupp. Byggeforskningen Rapport R 52 :1977
- 110 *Bring Ch och Roman B*: Invändiga ytskikt till väggar och tak. Funktionsanalys och provningsmetoder. Byggeforskningen Rapport R 9:1977
- 111 *Höglund I*: Elementär byggfysik — tillämpningsexempel. 1977
- 112 *Isakson P*: Plana termiska solfångare. En fysikalisk bakgrund. Byggeforskningen Rapport R 35:1978

- 113 Höglund I och Stillesjö S: Energibehov för bebyggelse — byggnadstekniska besparingsmöjligheter. 1978 (Särtryck ur Väg- och Vattenbyggaren nr 1-2, 1978)
- 114 Höglund I, Ekström L och Girdo V: Solvärme — energisparande och ekonomi. 1978 (Särtryck ur VVS-Forum nr 4 och 5, 1978)
- 115 Bring Ch: Provning av halksäkerhet. Stöd-krafter och rörelser hos foten vid habituell gång och halkning på klacken. 1978
- 116 Bring Ch: Hjulbelastning av industrigolv. Byggforskningen Rapport R 98:1978
- 117 Isakson P och Öfverholm E: Reporting Format for Solar Energy Buildings. Byggforskningen Document D 1:1977
- 118 Elmroth A: Well insulated airtight buildings. Design and construction. Byggforskningen Document D 10:1978
- 119 Girdo V: Grundläggande förutsättningar för soluppvärmning av byggnader i Skandinavien. Beräkningsmetod, parameteranalys, effektivitet och optimering. Byggforskningen Rapport R 108:1978
- 120 Carlsson B, Elmroth A och Engwall P-Å: Lufttät-het och värmeisolering — byggnadstekniska lösningar. Byggforskningen T 24:1979
- 121 Höglund I och Wänggren B: Funktionsstudier av tätningslister för fönster och dörrar. Bygg-forskningen T 7:1979
- 122 Höglund I och Girdo V: Calculations of Effi-ciency and Economy of Solar Heating Sys-tems in Scandinavian Climate. International Energy Agency, IEA. Investigation of the Per-formance of solar Heating and Cooling Pro-gram. Palermo meeting, Dec 1978
- 123 Höglund I och Wänggren B: Studies of the per-formance of weatherstrips for windows and doors. Byggforskningen Document D 4:1980
- 124 Höglund I, Johnsson B och Lagerström J: Ulv-sundaprojektet etapp 1. Effektivare energian-vändning i äldre byggnader. Byggforskning-en T 5:1981
- 125 Höglund I: A general presentation of the Department of Building Technology at the Royal Institute of Technology, Stockholm and of current energy research projects. 1979/80. (Särtryck ur SVR FoU-bygg 1980)
- 126 Höglund I och Wänggren B: Weatherstripping windows and doors. Calfeutrement des fenê-tres et des portes. (Reprinted from Building Research and Practice, Nov/Dec, 1979)
- 127 Girdo V: Solvärmesystem i Sverige inför 80-talet — analys av dagsläge och utvecklings-tendenser. (Särtryck ur Väg- och Vatten-byggaren nr 9, 1980)
- 128 Isakson P, Kennish W och Öfverholm E: Repor-ting format for thermal performance of solar heating and cooling systems in buildings. International Energy Agency, IEA. Bygg-forskningen Document D1:1980
- 129 Carlsson B, Elmroth A och Engwall P-Å: Air-tightness and thermal insulation — building design solutions. Byggforskningen Docu-ment D37:1980
- 130 Isakson P: Flat plate thermal solar collectors. Byggforskningen Document D35: 1980
- 131 Girdo V: Passiv solvärme för byggnadsupp-värmning — metod för beräkning av energi-besparing och självförsörjningsgrader. 1981
- 132 Höglund I och Nilsson S: Takteknik. 1981 (Byggförlaget)
- 133 Elmroth A, Forslund J och Rolén C: Energibe-sparing i bostadshus. 1981 (Särtryck ur Väg-och Vattenbyggaren nr 1, 1981)
- 134 Elmroth A: Technische Energiesparmassnah-men beim Bauen in Schweden. 1981 (Särtryck ur Architektur und Technik 8/1981)
- 135 Höglund I: Bygga om — spara energi. Energi-hushållning i teori och praktik. (Särtryck ur Byggindustrin 31.81) 1981
- 136 Elmroth A och Lögdberg A: Airtight Houses and Energy Consumption. Maisons étanches à l'air et consommation d'énergie. (Reprinted from Building Research and Practice March/April 1981)
- 137 Höglund I och Åhlgren B: Ombyggnadsteknik. (Teknisk högskolelitteratur, Stockholm AB, Kompendieförmedlingen) 1981
- 138 Elmroth A och Nylund P O: Fukt, täthet och ventilation. Utveckling av tekniska system. 1981 (Särtryck ur Byggindustrin 24, 1981)
- 139 Elmroth A och Levin P: Air Infiltration Control in Housing — A Guide to International Practice. International Energy Agency, IEA. Bygg-forskningen Document D2:1983
- 140 Höglund I: Värmebalansproblem hos fönster. (Särtryck ur Byggmästaren 2, 1983)
- 141 Höglund I: Energy-Saving in Existing Build-ings. (Reprinted from Building Research and Practice, Sept/Oct, 1983)
- 142 Höglund I, Wänggren B och Jansson B: Ombyggnad — med tonvikt på energihus-hållning. Presentation av två FoU-projekt. (Särtryck ur Bygg & Teknik 1/84)
- 143 Höglund I, Andersson P och Pettersson B O: Ombyggnad — med tonvikt på byggfysika-liska problem. Presentation av två FoU-projekt. (Särtryck ur Bygg & Teknik 2/84)
- 144 Höglund I, Pettersson B O och Åhlgren B: Fön-ster teknik. (Byggförlaget) 1985
- 145 Höglund I, Girdo V och Troedsson C G: Solin-strålningstabeller för helklara, halvklara och mulna typdagar. Strålning mot yttertor. Tim-värden och dygnsvärden 1985
- 146 Höglund I, Girdo V och Troedsson C G: Solin-strålningstabeller för helklara, halvklara och mulna typdagar. Transmitterad strål-nings genom fönster. Dygnsvärden 1984

- 147 *Girdo V*: Folier på befintliga och nya fönster. — Energisparmöjligheter. Byggforskningen R 87:1985
- 148 *Höglund I och Jansson B*: Joint Sealing Between Window (Door) Frames and Walls — development of new types of synthetic rubber stuffing strips. International Council for Building Research Studies and Documentation, CIB. Symposium on Windows in Building Design and Maintenance, Gothenburg, Sweden, 13-15 June 1984
- 149 *Ljunggren S*: Sound Insulation of Buildings with Large Slabs. (Reprinted from *Acustica* Vol. 60 1986)
- 150 *Höglund I, Ottoson G och Öman R*: Överglasning av stora byggnadsvolymer. — Skärholmens Centrum 1987
- 151 *Höglund I och Andersson P*: Additional Insulation of Flat Roofs with Thin-Walled Metal Structures. International Association for Bridge and Structural Engineering Colloquium on Thin-Walled Metal Structures in Buildings. Reprint from the Proceedings. 1986
- 152 *Pålsson A och Westerlund A*: En jämförelse mellan akustiska projekterings- och mätmetoder och subjektiv upplevelse i konsertsalar. 1987
- 153 *Höglund et al. 1988*. New Opportunities for Energy Conservation in Buildings - putting the results over a decade of research into practice. CIB W67 Energy Conservation in the Built Environment. Workshop. Stockholm 1987
- 154 *Höglund I och Ottoson G*: Takfönster på bättre sätt — sammanfattning av FoU-projektet "Takfönster och vindsvåningar". (Särtryck ur *Tidningen Byggindustrin* nr 40. 1988)
- 155 *Höglund I, Hyppel A och Franck L*: Operationen lyckades: Sjuka hus blev sunda hus. Sammanfattning av resultat från FoU-projektet "Nya saneringsmetoder för mögelskadade syllar". Stockholm 1989
- 156 *Höglund I & Ottoson G*: Roof Windows — Heat, Moisture and Air Transfer. International Centre for Heat and Mass Transfer. Symposium on "Heat and Mass Transfer in Building Material and Structure". Dubrovnik, Yugoslavia, 4-8 September 1989
- 157 *Ljunggren S*: Line Mobilities of Infinite Plates. Reprinted from *Journal of the Acoustical Society of America*, Vol. 86, No. 4, October 1989, Stockholm 1990
- 158 *Höglund I, Ottoson G och Öman R*: Glass Covering of Large Building Volumes. Commercial Shopping Centre. Pros and Cons. Reprinted from *Building Research and Practice*, No. 4, July/August 1989, Stockholm 1990
- 159 *Höglund I, Espling R & Hilding G*: Functional Studies of Flat Roofs Covered with Membranes of Butyl Rubber. CIB XI International Congress "Quality for Building Users Throughout the World" Paris, France, June 19-23 1989
- 160 *Höglund I, Ottoson G & Öman R*: Sigtunaprojektet: Energibalans för småhus med nya byggkomponenter. (Kompletterat särtryck ur *Bygg & teknik* 3/90. 1990)
- 161 *Levin P*: Building Technology and Air Flow Control in Housing. Byggforskningen Document D16: 1991
- 162 *Höglund I & Hyppel A*: Housing — renovation. New method of renovating wall sills damaged by mould. (Reprinted from *Building Research and Information*, Vol. 19, No 5, 1991)

The Department also publishes Working-Reports and Internal-Reports. Register of these papers can be ordered from the Department.