<http://www.diva-portal.org>

Preprint

This is the submitted version of a paper presented at *IEEE Jordan Conference on Applied Electrical Engineering and Computing Technologies (AEECT)* 3-5 Nov 2015.

Citation for the original published paper:

Hooshyar, H., Vanfretti, L. (2015)

Multiphase unbalanced power flow and fault analysis of distribution networks with high penetration of inverter-interfaced DERs.

In: IEEE

<http://dx.doi.org/10.1109/AEECT.2015.7360585>

N.B. When citing this work, cite the original published paper.

© 2015 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, in any current or future media, including reprinting/republishing this material for advertising or promotional purposes, creating new collective works, for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works.

Permanent link to this version:

<http://urn.kb.se/resolve?urn=urn:nbn:se:kth:diva-176654>

Multiphase Unbalanced Power Flow and Fault Analysis of Distribution Networks with High Penetration of Inverter-Interfaced DERs

Hossein Hooshyar* and Luigi Vanfretti**†

*KTH Royal Institute of Technology

Stockholm, Sweden

†Statnett SF

Oslo, Norway

hossein.hooshyar@ee.kth.se

Abstract— The traditional power flow and fault analysis methods fail to meet the requirements in both performance and accuracy aspects in the distribution network applications. This is due to the unbalanced multiphase nature of the distribution network and also due to the emerging penetration of renewable generation at the distribution level. This paper proposes a comprehensive method for power flow solution and fault analysis of multiphase unbalanced distribution networks with high penetration of inverter-interfaced DERs. Also, the self-protection scheme employed for the inverter of the DERs is also formulated in the proposed method. Performance of the proposed method has been assessed by simulations on a sample distribution network.

Keywords— *distribution network; distributed energy resources (DER); fault analysis; power flow; PSCAD/EMTDC.*

I. INTRODUCTION

The unbalanced multiphase characteristics of the distribution network together with the high penetration of distributed energy resources (DER) impose additional requirements to the traditional power flow and fault analysis methods. The Gauss-Seidel and Newton-Raphson techniques, and the traditional fault analysis methods such as sequence networks fail to meet performance and accuracy requirements for distribution network analysis studies. In particular, the assumptions resulting in the simplifications used in these standard methods are not valid in distribution networks [1,2].

New methods for power flow and fault analysis have been proposed in literature [1-7]. [3-5] propose solutions based on actual three-phase equations; however, system matrices are constructed in such way that power injection from DERs cannot be included. More advanced methods with the ability of considering DERs have been introduced in [1,6] but they are all valid for radial or, at most, weakly meshed networks.

This paper proposes a new comprehensive method performing both power flow and fault analysis for distribution networks of any kind of structure that are highly penetrated by inverter-interfaced DERs. The multiphase unbalanced nature of the distribution networks is also considered in the proposed method.

The paper begins with an introduction on the modeling principles in Section II. In Section III, the proposed method is introduced. Section VI evaluates the performance of the proposed method by comparing the results obtained from these methods and the results obtained from the PSCAD simulation on a test case. Conclusions are drawn in Section V.

II. MODELING PRINCIPLES

A. Basics

Fig. 1 shows a generic three phase line section. As shown in the figure, each phase is modeled by a PI section (Z_{sr}^{aa}, C_{sr}^a) and is coupled to other phases through mutual impedances (Z_{sr}^{ab}, Z_{sr}^{ac}). The current of the line section, I_{sr}^a , flows from the sending node, s , to the receiving node, r .

To each of these nodes, an inverter-interfaced DER and/or loads of different types, listed as follows, may be connected:

- Z_{CI} : Constant impedance load.
- I_{CC} : Constant current load.
- I_{CP} : Constant power load. The constant power load current is calculated as $I_{CP} = S^*/V$ where S is the load rating and V is the node voltage to which the load is connected.
- I_{DER} : Inverter-interfaced DER. The inverter is designed to push the power available from the DER (P_{DER}) to the power grid and also, in some cases, to exchange reactive power (Q) with the power grid as an ancillary service. So the current to be injected from the inverter for a specific active and reactive power is dependent on its terminal voltage (V) [2,8]. However, if this current gets to be higher than the maximum current rating of the inverter, inverter limits the current at its maximum level. So the inverter current can be described as $I_{DER} = f(P_{DER}, Q, V)$.

This work was supported in part by the FP7 IDE4L project funded by the European Commission, the STandUp for Energy Collaboration Initiative and by Statnett SF, the Norwegian TSO.

Fig. 2. Structure of the system matrices.

is a $N \times 1$ block matrix containing the line section currents as the system state variables, and $[ZI]$ is a $N \times 1$ block matrix containing the information of the loads and DERs connected to the line sections. Fig. 2 illustrates the structures of the matrices.

The line sections can be numbered in an arbitrary order. A building algorithm for these matrices can be developed as follows. Note that, in all equations throughout this paper, the numeric superscripts of the parameters represent the arbitrary number of the phases and should not be confused with *mathematical power*.

- $[Zbus]$: As shown in Fig. 2, $[Zbus]$ consists of N blocks of rows and N blocks of columns. The diagonal and off-diagonal blocks should be constructed as follows:

Diagonal blocks: Each diagonal block belongs to a line section and is sized as $k_i \times k_i$. (9) shows how to construct the diagonal block of a line section with k_i phases. (10), (11), and (12) are examples showing the diagonal blocks of a single-phase, a two-phase, and a three-phase line section, respectively.

$$[Zbus]_{k_i \times k_i}^{(i,i)} = \begin{bmatrix} Z_{sCI}^1 \parallel Zc_s^1 + Z_{sr}^{11} + Z_{rCI}^1 \parallel Zc_r^1 & \dots & Z_{sr}^{1k_i} \\ \vdots & \dots & \vdots \\ Z_{sr}^{1k_i} & \dots & Z_{sCI}^{k_i} \parallel Zc_s^{k_i} + Z_{sr}^{k_i k_i} + Z_{rCI}^{k_i} \parallel Zc_r^{k_i} \end{bmatrix} \quad (9)$$

$$[Zbus]_{1 \times 1}^{(i,i)} = [Z_{sCI}^a \parallel Zc_s^a + Z_{sr}^{aa} + Z_{rCI}^a \parallel Zc_r^a] \quad (10)$$

$$[Zbus]_{2 \times 2}^{(i,i)} = \begin{bmatrix} Z_{sCI}^a \parallel Zc_s^a + Z_{sr}^{aa} + Z_{rCI}^a \parallel Zc_r^a & Z_{sr}^{ab} \\ Z_{sr}^{ab} & Z_{sCI}^b \parallel Zc_s^b + Z_{sr}^{bb} + Z_{rCI}^b \parallel Zc_r^b \end{bmatrix} \quad (11)$$

$$[Zbus]_{3 \times 3}^{(i,i)} = \quad (12)$$

$$\begin{bmatrix} Z_{sCI}^a \parallel Zc_s^a + Z_{sr}^{aa} + Z_{rCI}^a \parallel Zc_r^a & Z_{sr}^{ab} & Z_{sr}^{ac} \\ Z_{sr}^{ab} & Z_{sCI}^b \parallel Zc_s^b + Z_{sr}^{bb} + Z_{rCI}^b \parallel Zc_r^b & Z_{sr}^{bc} \\ Z_{sr}^{ac} & Z_{sr}^{bc} & Z_{sCI}^c \parallel Zc_s^c + Z_{sr}^{cc} + Z_{rCI}^c \parallel Zc_r^c \end{bmatrix}$$

Off-diagonal blocks: The off-diagonal blocks, $(i, j)^{th}$ and $(j, i)^{th}$, sized as $k_i \times k_j$ and $k_j \times k_i$ respectively, refer to the interconnection between the i^{th} and the j^{th} line sections and should be constructed as shown in (13). If there is no interconnection between the i^{th} and the j^{th} line sections, the corresponding $(i, j)^{th}$ and $(j, i)^{th}$ blocks are null matrices.

$$[Zbus]_{k_i \times k_j}^{(i,j)} = ([Zbus]_{k_j \times k_i}^{(j,i)})^T = \begin{bmatrix} \pm (Z_{CI-cn}^1 \parallel Zc_{cn}^1) & \dots & 0 \\ \vdots & \dots & \vdots \\ 0 & \dots & \pm (Z_{CI-cn}^{k_i} \parallel Zc_{cn}^{k_i}) \end{bmatrix} \quad (13)$$

where subscript cn refers to the common node of i^{th} and j^{th} line sections. Note that the matrix entries in (13), Z_{CI-cn} and Zc_{cn} , are the constant impedance load and the total capacitive impedance at cn , respectively. The ‘ $\pm$ ’ sign is ‘ $+$ ’ if the line sections are interconnected via sending or receiving sides at the cn ; otherwise, i.e. one side is sending and the other side is receiving, it’s ‘ $-$ ’. Equations (14), (15), and (16) are examples showing the off-diagonal blocks corresponding to the connections between a single-‘a’-phase and a three-phase line section, a double-‘ab’-phase and a three-phase line section, and two three-phase line sections, respectively.

$$[Zbus]_{1 \times 3}^{(i,j)} = ([Zbus]_{3 \times 1}^{(j,i)})^T = [\pm (Z_{CI-cn}^a \parallel Zc_{cn}^a) \quad 0 \quad 0] \quad (14)$$

$$[Zbus]_{2 \times 3}^{(i,j)} = ([Zbus]_{3 \times 2}^{(j,i)})^T = \begin{bmatrix} \pm (Z_{CI-cn}^a \parallel Zc_{cn}^a) & 0 & 0 \\ 0 & \pm (Z_{CI-cn}^b \parallel Zc_{cn}^b) & 0 \end{bmatrix} \quad (15)$$

$$[Zbus]_{3 \times 3}^{(i,j)} = ([Zbus]_{3 \times 3}^{(j,i)})^T = \begin{bmatrix} \pm (Z_{CI-cn}^a \parallel Zc_{cn}^a) & 0 & 0 \\ 0 & \pm (Z_{CI-cn}^b \parallel Zc_{cn}^b) & 0 \\ 0 & 0 & \pm (Z_{CI-cn}^c \parallel Zc_{cn}^c) \end{bmatrix} \quad (16)$$

Finally note that the building algorithm of $[Zbus]$ is not based on the system topology, therefore the method can be used for both radial and meshed distribution networks.

- $[Iline]$: $[Iline]$ is a vector of N blocks as shown in Fig. 2. Each block, sized as $k_i \times 1$, contains the currents of the i^{th} line section as indicated in (17):

$$[Iline]_{k_i \times 1}^{(i)} = \begin{bmatrix} I_{sr}^1 \\ \vdots \\ I_{sr}^{k_i} \end{bmatrix} \quad (17)$$

- $[ZI]$: As shown in Fig. 2, $[ZI]$ is a vector of N blocks. Each block, sized as $k_i \times 1$, contains the information of the loads and DERs connected to the i^{th} line section as indicated in (18):

$$[ZI]_{k_i \times 1}^{(i)} = \begin{bmatrix} (Z_{sCI}^1 \parallel Z_c^1)(I_{sDER}^1 - I_{sCC}^1 - I_{sCP}^1) - (Z_{rCI}^1 \parallel Z_c^1)(I_{rDER}^1 - I_{rCC}^1 - I_{rCP}^1) \\ \vdots \\ (Z_{sCI}^{k_i} \parallel Z_c^{k_i})(I_{sDER}^{k_i} - I_{sCC}^{k_i} - I_{sCP}^{k_i}) - (Z_{rCI}^{k_i} \parallel Z_c^{k_i})(I_{rDER}^{k_i} - I_{rCC}^{k_i} - I_{rCP}^{k_i}) \end{bmatrix} \quad (18)$$

B. Incorporating Fault in System Matrices

Fig. 3 shows a generic fault, occurring at the arbitrary node s . As shown in the figure, applying a fault at s corresponds to adding the line section, sn . This leads to addition of a diagonal block, sized as $k_f \times k_f$, as the $(N+1)^{th}$ diagonal block entry of $[Zbus]$, as shown in Fig. 4. Also, for each line sections, connected to the faulted node s , two off-diagonal blocks are added to the $(N+1)^{th}$ row and the $(N+1)^{th}$ column. Fig. 4 shows the added off-diagonal blocks, sized as $k_f \times k_i$ and $k_i \times k_f$, assuming that the i^{th} line section is connected to the faulted node s . Determination of k_f and construction of the added blocks are done differently for grounded and ungrounded faults, as discussed below.

- **Grounded faults:** Following the same logic, used in Section II.B, deriving KVL equation for phase 'a', as shown by solid arrows in Fig. 3, leads to (19) if a single-'a'-phase to ground, (20) if a double-'ab'-phase to ground, and (21) if a three-phase to ground fault is applied.

$$-(Z_{sCI}^a \parallel Z_c^a) \sum_{i=1}^n I_{is}^a + (Z_{sCI}^a \parallel Z_c^a + R_f^a + R_f^g) I_f^a = (Z_{sCI}^a \parallel Z_c^a)(I_{sDER}^a - I_{sCC}^a - I_{sCP}^a) \quad (19)$$

$$-(Z_{sCI}^a \parallel Z_c^a) \sum_{i=1}^n I_{is}^a + (Z_{sCI}^a \parallel Z_c^a + R_f^a + R_f^g) I_f^a + R_f^g I_f^b = (Z_{sCI}^a \parallel Z_c^a)(I_{sDER}^a - I_{sCC}^a - I_{sCP}^a) \quad (20)$$

Fig. 3. Applying a generic fault at an arbitrary node.

$$[Zbus] = \begin{bmatrix} \boxed{\quad} & \cdots & \boxed{\quad} & 0 \\ \vdots & \ddots & \vdots & \vdots \\ \boxed{\quad} & \cdots & \boxed{\quad} & 0 \\ 0 & \cdots & 0 & \boxed{\quad} \end{bmatrix} \begin{matrix} N+1 \text{ blocks} \\ N+1 \text{ blocks} \end{matrix} \quad [Iline] = \begin{bmatrix} \boxed{\quad} \\ \vdots \\ \boxed{\quad} \\ \boxed{\quad} \end{bmatrix} \begin{matrix} k_1 \times 1 \\ \vdots \\ k_N \times 1 \\ k_f \times 1 \end{matrix} \begin{matrix} N+1 \text{ blocks} \end{matrix}$$

$$[ZI] = \begin{bmatrix} \boxed{\quad} \\ \vdots \\ \boxed{\quad} \\ \boxed{\quad} \end{bmatrix} \begin{matrix} k_1 \times 1 \\ \vdots \\ k_N \times 1 \\ k_f \times 1 \end{matrix} \begin{matrix} N+1 \text{ blocks} \end{matrix}$$

Fig. 4. Extension of system matrices as a result of applying a fault.

$$-(Z_{sCI}^a \parallel Zc_s^a \sum_{i=1}^n I_{is}^a + (Z_{sCI}^a \parallel Zc_s^a + R_f^a + R_f^g) I_f^a + R_f^g I_f^b + R_f^g I_f^c = (Z_{sCI}^a \parallel Zc_s^a) (I_{sDER}^a - I_{sCC}^a - I_{sCP}^a) \quad (21)$$

Similar equation to those shown by the solid arrows in Fig. 3 can be derived for other phases if any type of grounded faults is applied. Rearranging the derived equations into the form of matrix, results in the additional diagonal and off-diagonal blocks to be constructed as follows:

$$[Zbus]_{k_f \times k_f}^{(N+1, N+1)} = \begin{bmatrix} Z_{sCI}^1 \parallel Zc_s^1 + R_f^1 + R_f^g & \dots & R_f^g \\ \vdots & \dots & \vdots \\ R_f^g & \dots & Z_{sCI}^{k_f} \parallel Zc_s^{k_f} + R_f^{k_f} + R_f^g \end{bmatrix} \quad (22)$$

$$[Zbus]_{k_f \times k_i}^{(N+1, i)} = ([Zbus]_{k_i \times k_f}^{(i, N+1)})^T = \begin{bmatrix} \pm (Z_{sCI}^1 \parallel Zc_s^1) & \dots & 0 \\ \vdots & \dots & \vdots \\ 0 & \dots & \pm (Z_{sCI}^{k_f} \parallel Zc_s^{k_f}) \end{bmatrix} \quad (23)$$

where k_f is the number of faulted phases. As the faulted node s is always the sending side for the fault branch sn , the ' $\pm$ ' sign is '+' if the i^{th} line section is interconnected via its sending side; otherwise, it's '-'.

Equations (24) and (25), (26) and (27), and, (28) and (29) are examples showing the diagonal and off-diagonal blocks for a single-'a'-phase to ground, a double-'ab'-phase to ground, and a three-phase to ground fault, respectively. In all of these examples, it's assumed that the i^{th} line section, connected to the faulted node, is a three-phase line section.

$$[Zbus]_{1 \times 1}^{(N+1, N+1)} = [Z_{sCI}^a \parallel Zc_s^a + R_f^a + R_f^g] \quad (24)$$

$$[Zbus]_{1 \times 3}^{(N+1, i)} = ([Zbus]_{3 \times 1}^{(i, N+1)})^T = [\pm (Z_{sCI}^a \parallel Zc_s^a) \quad 0 \quad 0] \quad (25)$$

$$[Zbus]_{2 \times 2}^{(N+1, N+1)} = \begin{bmatrix} Z_{sCI}^a \parallel Zc_s^a + R_f^a + R_f^g & R_f^g \\ R_f^g & Z_{sCI}^b \parallel Zc_s^b + R_f^b + R_f^g \end{bmatrix} \quad (26)$$

$$[Zbus]_{2 \times 3}^{(N+1, i)} = ([Zbus]_{3 \times 2}^{(i, N+1)})^T = \begin{bmatrix} \pm (Z_{sCI}^a \parallel Zc_s^a) & 0 & 0 \\ 0 & \pm (Z_{sCI}^b \parallel Zc_s^b) & 0 \end{bmatrix} \quad (27)$$

$$[Zbus]_{3 \times 3}^{(N+1, N+1)} = \begin{bmatrix} Z_{sCI}^a \parallel Zc_s^a + R_f^a + R_f^g & R_f^g & R_f^g \\ R_f^g & Z_{sCI}^b \parallel Zc_s^b + R_f^b + R_f^g & R_f^g \\ R_f^g & R_f^g & Z_{sCI}^c \parallel Zc_s^c + R_f^c + R_f^g \end{bmatrix} \quad (28)$$

$$[Zbus]_{3 \times 3}^{(N+1, i)} = ([Zbus]_{3 \times 3}^{(i, N+1)})^T = \begin{bmatrix} \pm (Z_{sCI}^a \parallel Zc_s^a) & 0 & 0 \\ 0 & \pm (Z_{sCI}^b \parallel Zc_s^b) & 0 \\ 0 & 0 & \pm (Z_{sCI}^c \parallel Zc_s^c) \end{bmatrix} \quad (29)$$

(30) and (31) show the added blocks to $[Iline]$ and $[ZI]$, respectively.

$$[Iline]_{k_f \times 1}^{(N+1)} = \begin{bmatrix} I_f^1 \\ \vdots \\ I_f^{k_f} \end{bmatrix} \quad (30)$$

$$[ZI]_{k_f \times 1}^{(N+1)} = \begin{bmatrix} (Z_{sCI}^1 \parallel Zc_s^1) (I_{sDER}^1 - I_{sCC}^1 - I_{sCP}^1) \\ \vdots \\ (Z_{sCI}^{k_f} \parallel Zc_s^{k_f}) (I_{sDER}^{k_f} - I_{sCC}^{k_f} - I_{sCP}^{k_f}) \end{bmatrix} \quad (31)$$

- *Ungrounded faults:* Similar to the grounded-faults, KVL equations can be derived between the faulted phases as shown by the dotted arrows in Fig. 3. Rearranging the derived equations into the form of matrix, results in (32) to (35) showing the added blocks if ungrounded phase-to-phase fault is applied, and (36) to (39) showing the added blocks if ungrounded three-phase fault is applied. Note that, for ungrounded faults, k_f is equal to the number of faulted phases minus 1. This is because, in this type of faults, the number of independent fault current variables is always equal to the number of faulted phases minus 1.

$$[Zbus]_{1 \times 1}^{(N+1, N+1)} = [Z_{sCI}^1 \parallel Zc_s^1 + R_f^1 + R_f^2 + Z_{sCI}^2 \parallel Zc_s^2] \quad (32)$$

$$[Zbus]_{1 \times k_i}^{(N+1, i)} = ([Zbus]_{k_i \times 1}^{(i, N+1)})^T = [0 \dots \pm (Z_{sCI}^1 \parallel Zc_s^1) \dots 0 \dots \mp (Z_{sCI}^2 \parallel Zc_s^2) \dots 0] \quad (33)$$

$$[Iline]_{1 \times 1}^{(N+1)} = [I_f^{12}] \quad (34)$$

$$[ZI]_{1 \times 1}^{(N+1)} = [(Z_{sCI}^1 \parallel Zc_s^1) (I_{sDER}^1 - I_{sCC}^1 - I_{sCP}^1) - (Z_{sCI}^2 \parallel Zc_s^2) (I_{sDER}^2 - I_{sCC}^2 - I_{sCP}^2)] \quad (35)$$

$$[Zbus]_{2 \times 2}^{(N+1, N+1)} = \begin{bmatrix} Z_{sCI}^1 \parallel Z_c^1 + R_f^1 & -(Z_{sCI}^2 \parallel Z_c^2) - R_f^2 \\ Z_{sCI}^3 \parallel Z_c^3 + R_f^3 & Z_{sCI}^2 \parallel Z_c^2 + R_f^2 + R_f^3 + Z_{sCI}^3 \parallel Z_c^3 \end{bmatrix} \quad (36)$$

$$[Zbus]_{2 \times k_i}^{(N+1, i)} = ([Zbus]_{k_i \times 2}^{(i, N+1)})^T = \begin{bmatrix} \pm(Z_{sCI}^1 \parallel Z_c^1) & \mp(Z_{sCI}^2 \parallel Z_c^2) & 0 \\ 0 & \pm(Z_{sCI}^2 \parallel Z_c^2) & \mp(Z_{sCI}^3 \parallel Z_c^3) \end{bmatrix} \quad (37)$$

$$[Iline]_{2 \times 1}^{(N+1)} = \begin{bmatrix} I_f^{12} \\ I_f^{23} \end{bmatrix} \quad (38)$$

$$[ZI]_{2 \times 1}^{(N+1)} = \begin{bmatrix} (Z_{sCI}^1 \parallel Z_c^1)(I_{sDER}^1 - I_{sCC}^1 - I_{sCP}^1) - (Z_{sCI}^2 \parallel Z_c^2)(I_{sDER}^2 - I_{sCC}^2 - I_{sCP}^2) \\ (Z_{sCI}^2 \parallel Z_c^2)(I_{sDER}^2 - I_{sCC}^2 - I_{sCP}^2) - (Z_{sCI}^3 \parallel Z_c^3)(I_{sDER}^3 - I_{sCC}^3 - I_{sCP}^3) \end{bmatrix} \quad (39)$$

C. Calculation of System Voltage

As discussed in Section II.A, the currents of the line sections, $[Iline]$, are obtained through (8). Using the calculated currents together with the information of DERs and loads, the node voltages can be easily determined. (40) gets the voltage of an arbitrary phase 'a' node illustrated in Fig. 5. The calculated node voltages will be then used to update the values of the currents of DERs and constant power loads.

$$V_a = (Z_{sCI}^a \parallel Z_c^a) \left(I_{sDER}^a + \sum_{i=1}^n I_i^a - I_{sCC}^a - I_{sCP}^a \right) \quad (40)$$

Fig. 5. DER and loads connected to an arbitrary phase 'a' node.

D. The Proposed Method

Fig. 6 shows the proposed algorithm for the power flow solution of a distribution network with high penetration of DERs. As shown in the figure, the network solution, proposed

in the previous Sections, calculates the state variables, $[Iline]$, from which the bus voltages, $[V]$, are determined. The bus voltages are then passed to the models of DERs and constant power load, introduced in Section II, to update the values of the currents of DERs and constant power loads. This iteration runs until convergence is reached. Note that the characteristics of constant impedance and constant current loads do not need to be updated as they are represented with constant values in the network solution.

The algorithm, illustrated in Fig. 6, gives the power flow solution and can also be used for the fault analysis as the fault can be modeled in system matrices. However, the values given for fault analysis are valid only for the first moments after the fault occurrence. This is because the DERs employ self-protection systems which disconnect them from the grid in such conditions. The disconnection time for different DERs is not the same as, for each DER, it depends on DER's distance to the fault and also the type of the employed self-protection system. Hence, as a result of DERs disconnecting at different times from the grid, the fault currents will be varying [2]. Thus, in order to be able to determine such a fault current profile, the proposed algorithm is extended, as shown in Fig. 7. As shown in the figure, the response of the DER self-protection is emulated in each iteration in order to determine the DERs that will be disconnected by their protection system, and how long it will take for the protection system to disconnect them. This loop is repeated until the DER protection does not disconnect any more DER.

Fig. 6. Power flow solution for a multiphase unbalanced DER-dominated distribution network.

IV. TEST CASE

To evaluate the performance of the proposed methods on a multiphase unbalanced distribution network, the IEEE 34 node test feeder is used as the test case in this study. Since the original test feeder contains only radial sub-feeders, a number of lines have been added to create a meshed distribution network. Fig. 8 shows the modified test feeder. It's assumed that each customer has a PV system (as DER) that can generate up to its maximum load of the customer unit (100% penetration). For this study, this system is simulated using PSCAD in order to get detailed time domain responses and to use them for comparison with the proposed method.

The PV system is simulated by adopting a typical model, which uses average models for the converters, and includes maximum power point tracking [9]. The PVs' self-protection system is IEEE 929 complaint [10].

Fig. 7. Fault analysis for a multiphase unbalanced DER-dominated distribution network.

Tables I to IV compare the results from the proposed methods with the results obtained from PSCAD simulations for a number of selected nodes. The simulation results have been gathered after the initial transients were damped. The results are obtained for two different conditions of zero PV generation at night and maximum PV generation at noon. These results show that the proposed methods estimates are very close to the ones from simulations. As indicated in the tables, the maximum difference between the results calculated by the proposed method and obtained from the simulations is less than 1.4%.

Note that when the PVs generation are at the maximum level, the fault currents will have two different values, as shown in Table IV. This is because, due to low system voltage during the fault, the PVs self-protections disconnect the PV systems from the grid 0.1s after the fault occurrence which, in turn, results in a step in the fault current profile. Fig. 9 shows such changes in the fault current profile for a three-phase fault occurring at node 862 with fault resistance of 3Ω . As shown in the figure, the transients captured by the simulation results are not included in calculated results. Also, the simulations results

contain the inherent delay of the RMS measuring blocks which does not exist in the results obtained from the proposed method.

It is worth noting that the proposed method and also the test feeder have been coded in MATLAB to calculate the presented power flow and fault analysis results.

V. CONCLUSION

This paper proposed a new comprehensive method for power flow solution and fault analysis of multiphase unbalanced distribution networks with high penetration of inverter-interfaced DERs. The proposed method can be used for distribution networks of any kind of structure, i.e. radial and meshed. Also, the self-protection scheme employed for the

TABLE I. POWER FLOW RESULTS (NO PV-NIGHT)

Node	Phase	$ V _{p.u.}$ (Simulation)	$ V _{p.u.}$ (Proposed Method)	$\angle V$ deg. (Simulation)	$\angle V$ deg. (Proposed Method)
802	a	0.9974	0.9974	-0.0333	-0.0333
	b	0.9976	0.9976	-120.0505	-120.0505
	c	0.9978	0.9978	119.9542	119.9542
816	a	0.9124	0.9124	-0.8528	-0.8528
	b	0.9568	0.9568	-120.2738	-120.2736
	c	0.9214	0.9214	119.6667	119.6667
862	a	0.8607	0.8607	-0.9947	-0.9969
	b	0.9315	0.9315	-119.9604	-119.9592
	c	0.8486	0.8486	119.946	119.9459
		Max. Dif. = 0.0000%		Max. Dif. = 0.2212%	

TABLE II. POWER FLOW RESULTS (MAX. PV-NOON)

Node	Phase	$ V _{p.u.}$ (Simulation)	$ V _{p.u.}$ (Proposed Method)	$\angle V$ deg. (Simulation)	$\angle V$ deg. (Proposed Method)
802	a	0.999	0.999	0.0647	0.0654
	b	0.9989	0.9989	-119.9514	-119.9507
	c	0.999	0.999	120.0501	120.0507
816	a	0.9697	0.9702	2.3249	2.3444
	b	0.9859	0.9861	-118.9451	-118.9369
	c	0.9746	0.9751	122.203	122.2142
862	a	0.9542	0.955	3.8982	3.9259
	b	0.9818	0.9822	-118.1724	-118.1625
	c	0.9575	0.9584	124.5343	124.5512
		Max. Dif. = 0.0940%		Max. Dif. = 1.0819%

Fig. 8. Test case – Modified IEEE 34 node test feeder.

inverter of the DERs can be formulated in the proposed method. As shown in the paper, the maximum difference between the results calculated by the proposed method and obtained from the simulations is less than 1.4%, indicating that the method provides quite accurate estimates with low computational burden when contrasted to PSCAD simulation.

TABLE III. FAULT CURRENT VALUES (NO PV-NIGHT)

Node	Phase	$R_f = 0\Omega$			
		<i>If</i> -3LG (kA) (Simulation)	<i>If</i> -3LG (kA) (Proposed Method)	<i>If</i> -LG (kA) (Simulation)	<i>If</i> -LG (kA) (Proposed Method)
802	a	16.1057	16.105	12.7462	12.7457
	b	17.3865	17.3857	-	-
	c	16.4279	16.4272	-	-
816	a	0.4941	0.4941	0.3982	0.3982
	b	0.7308	0.7309	-	-
	c	0.5176	0.5176	-	-
862	a	0.2526	0.2526	0.2119	0.2119
	b	0.4867	0.4868	-	-
	c	0.2667	0.2666	-	-
$R_f = 3\Omega$					
802	a	3.8895	3.8894	3.7889	3.7888
	b	3.9861	3.9861	-	-
	c	3.9636	3.9635	-	-
816	a	0.4483	0.4483	0.3725	0.3725
	b	0.6473	0.6474	-	-
	c	0.4728	0.4728	-	-
862	a	0.2383	0.2383	0.2035	0.2035
	b	0.4467	0.4468	-	-
	c	0.2524	0.2524	-	-
		Max. Dif. = 0.0375%		Max. Dif. = 0.0039%	

TABLE IV. FAULT CURRENT VALUES (MAX. PV-NOON)

Node	Phase	$R_f = 0\Omega$			
		<i>If</i> -3LG (kA) (Simulation)	<i>If</i> -3LG (kA) (Proposed Method)	<i>If</i> -LG (kA) (Simulation)	<i>If</i> -LG (kA) (Proposed Method)
802	a	16.1335	16.1559	12.715	12.7382
		16.1057	16.105	12.7445	12.744
	b	17.3322	17.3167	-	-
		17.3865	17.3857	-	-
816	c	16.4434	16.4416	-	-
		16.4279	16.4272	-	-
	a	0.486	0.4924	0.3411	0.3458
		0.4941	0.4941	0.3945	0.3946
862	b	0.779	0.7735	-	-
		0.7308	0.731	-	-
	c	0.469	0.4703	-	-
		0.5176	0.5177	-	-
862	a	0.3194	0.317	0.2615	0.2601
		0.2615	0.2615	0.2164	0.2162
	b	0.541	0.5444	-	-
		0.4864	0.4866	-	-
862	c	0.3225	0.3221	-	-
		0.2665	0.2665	-	-

$R_f = 3\Omega$					
802	a	3.8976	3.8978	3.7978	3.798
	b	3.9938	3.9939	-	-
	c	3.9701	3.9702	-	-
816	a	0.5187 0.4483	0.5171 0.4483	0.4177 0.3691	0.4169 0.3691
	b	0.7036 0.6474	0.6987 0.6475	-	-
	c	0.5127 0.4728	0.5124 0.4729	-	-
862	a	0.3006 0.2467	0.3003 0.2467	0.2633 0.2077	0.2604 0.2076
	b	0.5105 0.4464	0.5077 0.4465	-	-
	c	0.3217 0.2522	0.3195 0.2523	-	-
		Max. Dif. = 1.3169%		Max. Dif. = 1.3779%

Fig. 9. Fault current profile for a three-phase fault at node 862 with $R_f = 3\Omega$.

A. References

- [1] J. Teng, "A direct approach for distribution system load flow solutions," *IEEE Transactions on Power Delivery*, vol. 18, no. 3, pp. 882–887, July 2003.
- [2] H. Hooshyar, M. E. Baran, "Fault analysis on distribution feeders with high penetration of PV systems," *IEEE Trans. Power Sys.*, vol. 28, no. 3, pp. 2890–2896, Aug. 2013.
- [3] S.M. Halpin, "Fault analysis of multi-phase unbalanced nonradial power distribution systems," *IEEE Transactions on Industry Applications*, vol. 31, no. 3, pp. 528–534, May/June 1995.
- [4] R.M. Ciric, "Fault analysis in four-wire distribution networks," *IEE Proceedings on Generation Transmission and Distribution*, vol. 152, no. 6, pp. 977–982, Nov. 2005.
- [5] K.S. Swarup, "Unbalanced distribution system short circuit analysis — an object-oriented approach," *IEEE TENCON Conference*, pp. 1–6, 19–21 Nov. 2008.
- [6] J. Teng, "Systematic short-circuit-analysis method for unbalanced distribution systems," *IEE Proceedings on Generation Transmission and Distribution*, vol. 152, no. 4, pp. 549–555, July 2005.
- [7] M. E. Baran, H. Hooshyar, Z. Shen, A. Huang, "Accommodating high PV penetration on distribution feeders," *IEEE Transactions on Smart Grid*, vol. 3, no. 2, pp. 1039–1046, June 2012.
- [8] Q. Wang, N. Zhou, L. Ye, "Fault analysis for distribution networks with current-controlled three-phase inverter-interfaced distributed generators," *IEEE Transactions on Power Delivery*, vol. 30, no. 3, pp. 1532–1542, June 2015.
- [9] Model available on the website of ECEE department at the University of Colorado at Boulder (<http://ecee.colorado.edu/~ecen2060/matlab.html>).
- [10] IEEE 929, "IEEE recommended practice for utility interface of photovoltaic (PV) systems", 2000.